

Universal Waste Storage Area Management Guidelines

1. Each individual waste container or waste material must be properly labeled.
2. All containers must be in good condition and free of any defects (rust, punctures, leaks, dents, etc).
3. All containers must be managed such that the waste label is visible for inspection at all times.
4. If you have questions about the management of any waste contact EH&S at 2-2818.

Waste Materials	Collection Instructions	Container Label Information	Comments
Batteries	-Place tape on terminals to prevent accidental contact. -		

Waste Materials	Collection Instructions	Container Label Information	Comments
Mercury thermostats	<ul style="list-style-type: none"> -Intact thermostats should be placed in an appropriately sized closable pail or jar. -Containers must be closed unless actively adding units. 	<ul style="list-style-type: none"> - 3 8 Q L Y H U V D O : D V W H ´ - 3 / D P S V ´ -Generator information -Accumulation start date 	
<p>Used oil and combustible liquids (#2 fuel oil, motor oil, hydraulic oil, gear oil, transmission fluid, diesel fuel)</p> <p>Aerosol cans for disposal</p>	<ul style="list-style-type: none"> -Pour used oils and other combustible liquids into 55-gallon drum on spill pallet or smaller containers in secondary containment. -Do not mix with other solvent or degreasers. 	<ul style="list-style-type: none"> - 3 8 V H G 2 L O ´ - Generator information 	<p>All oil drums 55 gallons or larger must be stored on secondary containment pallet. If reusing empty drums for another purpose, drum labels must be changed to indicate new material being contained.</p>